



**BANGLADESH-INDIA FRIENDSHIP POWER COMPANY (PVT.) LIMITED**  
 (A JOINT VENTURE OF BPDB & NTPC LTD.)  
 Registered Office: Borak Unique Heights (Level-17),  
 117, Kazi Nazrul Islam Avenue, Dhaka-1217, Bangladesh

**Tender: EPC Township Package for 2x660MW Maitree Super Thermal Power Project at Rampal, Bagerhat**

**Subject: Technical Clarification for Bid Queries**

**Document No.: BIFPCL/ MSTPP/ EPC TOWNSHIP- CLRF.04 Dated 13.09.2018**

S. No.	Volume	Part	Section	Clause No.	Page No.	Specification Requirement	Bidder's Query	Employer's Clarification
1		A	2	Annexure - 1 and Note 6	49	Minimum 2 numbers of batching plant of capacity 30 Cum/hr. to be maintained till completion and handing over of priority area as listed in time schedule. The same may be reduced to 1 later as per the job requirements and as approved by the Engineer in Charge.	We request you to make this As Required So, we would be able to mobilize required capacity plant(s) as per project requirement and construction schedule to achieve the stipulated timeline.	Second sentence in Note-6 clearly says "The same may be reduced to 1 later as per the job requirements and as approved by the Engineer in Charge."
2		B	B1	4.6	12 of 45	The Contractor shall identify sufficient area outside the Township boundary to locate his staff and labour colony.	By looking scope of work and timeline of the project, we request you to allow as to setup labour camp at site So, transit time from Camp to Site and vice versa shall be reduced.	Labour colony shall not be inside the site. Bidder to comply with Specification.
3		B	B0	2.2	9 of 44	Any other buildings, structures and works necessary and not specifically mentioned here but required for construction, operation and maintenance of the township are deemed to be included in the scope of the contractor.	Please provide exact scope of work and any other structure shall be required at later stage shall be treated as New work / Extra work / Additional work.	All major buildings and structures required in the Township are already listed. This clause is to cover any small structures, annexes, sheds, etc required for completion of Township facilities.
4		B	B0	2.5	10 of 44	The Contractor shall fill or excavate the areas to the required formation levels as indicated in the plot plan and dispose the excavated materials as directed by the Owner, without any extra cost to the Owner.	Please provide disposal location. Also we assume that necessary permission for disposal in Client's scope please confirm.	Disposal location shall be finalized during execution within our existing land, as much as possible. All statutory requirement is the sole responsibility of the Contractor. Refer Clause number 14, page 43 of 44, part B, section B0.
5		B	B4		49		Please provide floor to floor height for all the structure.	This shall be decided during detailed engineering considering clear head rooms required in respective facilities.

*DM*